

CERTIFICATE OF COMPLIANCE

Certificate Number 20151215-E356500
Report Reference E356500-20151214
Issue Date 2015-DECEMBER-15

Issued to: SOFTING AG
RICHARD-REITZNER-ALLEE 6
85540 HAAR GERMANY

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

Class I, Division 2 Groups A,B,C and D.

Enclosed Type Fieldbus Gateways Model – FG-200
HSE/FF

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 213-15, Non-Incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous
Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

